

Ref: SSS 08.1.1
SPECIFICATION SELECTION SHEET
MODEL 141-A
FIELD REGULATOR



Energy Metering

141 Models	Description	Code
141-A	Standard Regulator	A1

Pipe Size	Code
2"	B1

Outlet Pressure Range	Spring Color	Code
5 p.s.i.g. to 12 p.s.i.g.	Yellow	C1
10 p.s.i.g. to 50 p.s.i.g.	Aluminium	C2
50 p.s.i.g. to 150 p.s.i.g.	White	C3
100 p.s.i.g. to 250 p.s.i.g.	Green	C4
200 p.s.i.g. to 400 p.s.i.g.	Tan	C5
400 p.s.i.g. to 600 p.s.i.g.	Gray	C6

Orifice size	Code	Trim	Code
1/8"	D1	Brass	E1
1/4"	D2	S. Steel	E2
3/8"	D3		
1/2"	D4		
5/8"	D5		
7/8"	D6		

Special Instructions:

Please reference specification bulletin R 1311 for full specification details.
Please circle your choice in each category or include code choices on your purchase order.
Standard Construction and Testing at Manufacturer's Recommended settings will apply unless otherwise specified above. AGA Gray paint finish is supplied unless otherwise specified.

Purchase Order No.	
---------------------------	--